

Annual Drinking Water Quality Report

SANDY SPRINGS WATER DISTRICT (0420003)

SC0420003

Annual Water Quality Report for the period of January 1 to December 31, 2016.

This report is intended to provide you with Important information about your drinking Water and the efforts made by the water System to provide safe drinking water.

The source of drinking water used by SANDY SPRINGS WATER DISTRICT (0420003) is Purchased Surface Water.

For more information regarding this report contact:
Tracy Durham
864-646-7729

Este informe contiene informacion muy importante Sobre el agua que usted bebe. Traduzcalo o hable con Alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

-Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

-Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

-Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

-Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

-Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

<u>Source Water Name</u>	<u>Type of Water</u>	<u>Location</u>
0420004 HIGHWAY 88 W/D (P04109)	SW	6910 Hwy. 76, Pendleton, SC 29670
0420011 ANDERSON REGIONAL W/S	SW	998 Hunters Trail, Anderson, SC 29625

2015 REGULATED CONTAMINANTS DETECTED

Lead & Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead & Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2016	1.3	1.3	0.190000000	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2016	0	15	0.860000000	0	ppb	N	Corrosion of household plumbing. Erosion of natural deposits.

Water Quality Test Results

- Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
- Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.
- ppm: milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
- ppb: micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
- na: not applicable.
- Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2016	24	12.1 – 41.4	No goal for the total	60	ppb	N	By-Product of drinking water disinfection.

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Total Trihalomethanes (TTHM)	2016	31	12.9 – 49.5	No goal for the total	80	ppb	N	By-Product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Inorganic Contaminant Test Results	Violation Y/N	Level Detected	Range of Detection	Unit Measurement	MCLG	MCL	
Nitrate	No	0.39 ECWD (2016)	0.39	PPM	10	10	Runoff from fertilizer use; Leaching from septic tanks, Sewage; Erosion of natural deposits.
	No	0.24 ARJWS (2016)	0.24	mg/L	10	10	Runoff from fertilizer use; Leaching from septic tanks, Sewage; Erosion of natural deposits.
Flouride	N	0.42 ARJWS (2016)	0-03.52	mg/L	4	4	Erosion of natural deposits; water additive which Promotes strong teeth; discharge from fertilizer and Aluminum factories.
	N	0.50 ECWD (2016)	N/A	mg/L	4	4	
Total Organic Carbon (ARJWS)	N	<u>41% removal</u> <u>*35% required</u>	1.15-2.30 mg/l removal	1.54 mg/l	Monthly	TT Step 1	Naturally present in the environment
Total Organic Carbon (ECWD)	N	Met requirements.		TT	TT		Decay of natural deposits.
Chlorine (2016)	N	(ARJWS) RAA-1.57	1.52-1.65	PPM		4	Water additives used to control microbes.
	N	(ECWD) RAA-1.88	N/A	MG/L	(MRDLG=4)	(MRDL=4)	